

Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address:	SHENZHEN GROWATT NEW ENERGY TECHNOLOGY CO., LTD 2th Floor, B Building, BaFangYuan Techonlogy Park, SanMin Road, Shiyan Town, BaoAn District, ShenZhen, P.R.China
Product Description:	PV Grid-connected inverter
Ratings & Principle Characteristics:	See Annex to Test Verification of Conformity
Models:	Growatt 3000-S, Growatt 2000-S
Brand Name:	Growatt(logo)
Relevant Standards	See Annex to Test Verification of Conformity
Verification Issuing Office:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China
Date of Tests:	14 Jun 2016 – 24 Jun 2016
Test Report Number(s):	160613152GZU-001

This verification is part of the full test report(s) and should be read in conjunction with them.



Signature

Name: Grady Ye
Position: Assistant Manager
Date: 27 Jun 2016

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with Verification/Report Number(s):
 160613152GZU-001. the issuing office is Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
 (Address: Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD,
 Guangzhou, China).

Ratings & Principle Characteristics:	Model	Growatt 3000-S	Growatt 2000-S
Max. DC input Voltage:		550Vdc	450
Max. input current:		13A	11A
DC input range:		70-550Vdc	70-450Vdc
Nominal AC output voltage:		230Vac	230Vac
Nominal frequency:		50Hz	50Hz
AC output power:		3000W	2000W
Nominal AC output current:		13A	8.7A
Power factor:		>0.99	>0.99
Ingress protection:		IP65	IP65
Protection Class:		Class I	Class I
Operation Ambient Temp.:		-25°C to +60°C	-25°C to +60°C



Signature

Name: Grady Ye
 Position: Assistant Manager
 Date: 27 Jun 2016

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with Verification/Report Number(s):
160613152GZU-001. the issuing office is Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
(Address: Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD,
Guangzhou, China).

Relevant Standards:

IEC 60068-2-1:2007, Environmental testing – Part 2-1: Tests-
Test A: Cold

IEC 60068-2-2:2007, Environmental testing – Part 2-2: Tests-
Test B: Dry heat

IEC 60068-2-14:2009, Environmental testing – Part 2-14:
Tests- Test N: Change of temperature

IEC 60068-2-30:2005, Environmental testing – Part 2-30:
Tests- Test Db: Damp heat, cyclic(12h +12h cycle)

IEC 61683: 1999, Photovoltaic systems – Power conditioners
– Procedure for measuring efficiency



Signature



Name: Grady Ye
Position: Assistant Manager
Date: 27 Jun 2016

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.